

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

Fax No. 011-23412593, Ph. 011-23412225

No. F.6 DFS/MS/School/2018/SZ/ 404

Dated: 13/3/18

FIRE SAFETY CERTIFICATE

Certified that **Kalka Public School** located at **Alaknanda, Kalkaji, New Delhi-110019**, having two interconnected blocks comprised of (1) Lower ground floor, ground plus three upper floors and (2) Basement, ground plus three upper floors **Owned/Occupied** by Kalka Public School was inspected by the officer concerned of this department on 22/02/2018 in presence of Sh. Anil Mehrotra (Chairman) and found that the school building **except auditorium** have complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular No. 262-362 dated 17/01/2005 issued by Director of Education, Govt. of NCT of Delhi and that the school building is fit for occupancy class "**Educational Building**" Group-B, as above with effect from the date of issue of this certificate for a period of **Three years**, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 13/3/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer

Copy to: -

1. The Chairman, Kalka Public School, Alaknanda, Kalkaji, New Delhi-110019
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. This FSC is not valid for Auditorium and same shall not be used by the school Authority.
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."