

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/School/2024/SZ/62

Dated: 25/01/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Kalka Public School**, located at **Alaknanda Kalkaji, New Delhi-110019** having two interconnected blocks Comprised of South Block- Lower Ground, Ground plus three upper floors & North Block- Basement, Ground + Three Upper Floors was issued FSC by this department vide letter No. F6/DFS/MS/School/2018/SZ/404 Dated 13-03-2018. The said premise was re-inspected by officer concerned of this department on 09/01/2024 in presence of Mr. Anil Malhotra and found that the North block building is comprised of Basement, Ground plus three upper floor with 4<sup>th</sup> floor (Under construction) have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No 262-362 dated 17/01/2005 issued by Director of Education, Govt. of NCT of Delhi and the building is fit for occupancy class "**Educational Building Group - B**" (Two interconnected blocks, South Block- Lower Ground, Ground plus three upper floors & North Block- Basement, Ground + Three Upper Floors) with effect from 25/01/2024 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued 25/01/2024 at New Delhi by

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. The Manager, Kalka Public School, located at Alaknanda Kalkaji, New Delhi-110019
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-54.

**Conditions for the validity of Fire Safety Certificate: -**

1. The occupancy above 3<sup>rd</sup> floor is (i.e. 4<sup>th</sup> floor) not allowed for any activity.
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. The basement shall be used as per the provisions of BBL /NBC Part- IV
5. All the staff members must know the correct method of operation of fire fighting system.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."